

Tester:	Jinglan Zeng			Date:	11/Sep/2023
1	Item number			62/1746/EM	
2	Power source			2pcs IFR18650 2000mAh 3.2V	
3	Input frequency			NA	
4	Power supply properties			Emergency Power Supply	
5	Lux meter			EVERFINE Z-10	
6	Number of samples			1pc	
7	Voltage of full charged batteries without load			7.3V	
				Equipment Model	Illuminance Meter
					EVERFINE Z-10
Time(min)	3000K Lux *200cm, **60cm	% of Lux	***Lux 220cm Center		Remark
Battery ON	23.5				Charge for 24 H, the green light is on, 100% complete charge, collect the luminance value corresponding to the color temperature at different points in time. *Light cone height 200cm **Radius of the base of the light cone 30cm ***Center of the base of the light cone
0	23.5	100.0%	99.2		
15	23.1	98.3%	97.3		
20	21.3	90.6%	90.0		
30	18.0	76.6%	76.0		
40	17.9	76.2%	75.7		
50	14.5	61.7%	61.0		
60	12.7	54.0%	63.7		
70	12.7	54.0%	53.5		
80	10.9	46.4%	46.0		
90	10.9	46.4%	46.0		
130	0.0	0.0%	0.0		
130	Light off				
Tester: Jinglan Zeng Chen		Auditor: Jinglan Zeng			Approved by: Shunyang
Trend:					

