

Tester:	Jinglan Zeng			Date:	11/Sep/2023
1	Item number			62/1756/EM	
2	Power source			3pcs IFR18650 2000mAh 3.2V	
3	Input frequency			NA	
4	Power supply properties			Emergency Power Supply	
5	Lux meter			EVERFINE Z-10	
6	Number of samples			1pc	
7	Voltage of full charged batteries without load			11.2V	
				Equipment Model	Illuminance Meter
					EVERFINE Z-10
Time(min)	3000K Lux *200cm, **60cm	% of Lux	***Lux 200cm Center		Remark
Battery ON	37.8				Charge for 24 H, the green light is on, 100% complete charge, collect the luminance value corresponding to the color temperature at different points in time. *Light cone height 200cm **Radius of the base of the light cone 30cm ***Center of the base of the light cone
0	37.8	100.0%	123.6		
15	37.4	98.9%	122.4		
20	35.0	92.6%	112.2		
30	33.0	87.3%	107.7		
40	32.9	87.0%	107.5		
50	29.9	79.1%	97.6		
60	28.6	75.7%	93.5		
70	28.7	75.9%	93.9		
80	23.3	61.6%	76.2		
90	17.5	46.3%	57.2		
124	0.0	0.0%	0.0		
124	Light off				
Tester: Jinglan Zeng Chen		Auditor: Jinglan Zeng			Approved by: Shunyang
Trend:					

